

## ADDENDUM ONE

ISSUANCE DATE: 4/12/18

Peoria Park District  
Planning, Design and Construction Department  
1314 N. Park Road  
Peoria, IL 61604  
Telephone: (309) 686-3386

ADDENDUM NO. 1

PROJECT TITLE: ROOF REPLACEMENT  
DONOVAN PARK CLUBHOUSE-  
UPPER ROOF

Architect:  
ApacDesign Architects + Engineers  
2112 E. War Memorial Dr.  
Peoria, IL 61614-8002

LOCATION: Donovan Park

The proposed Contract Documents for this Work are modified as follows:

I. **DRAWINGS:**  
N/A

II. **PROJECT MANUAL/SPECIFICATIONS/GENERAL CONDITIONS/ETC.:**

GENERAL ITEMS/CLARIFICATIONS:

- A. All insulation is adhered and Grade 3 as specified.
- B. Insulation shall be an approved insulation by the Roofing Manufacturer, including meeting requirements of the Project Manual.

SPECIFICATIONS:

- A. Section 075216 - (SBS) Modified Membrane Roofing:
  - 1. Add the following Johns Mannville system:
    - a. Reference 2.3.A.1.b: Add DynaBase; 91 mil. thickness.
    - b. Reference 2.4.A.1.b: Add Dynalastic 180 FR CR G; 157 mil. thickness.

II. **INVITATION TO BID:**  
N/A

END OF ADDENDUM NO. 1

(Addendum may be bound into Project Manual, attached to front cover, faxed, emailed or delivered to bidders.)